



MONTHLY REPORTING PERIOD - MAY, 2024

SUMMARY

This document provides a summary of the water quality information collected by BMID in May 2024. Documentation and figures are provided on the following pages to support this submission.

WATER SUPPLY & USAGE SUMMARY

1. Water usage data for May, 2024 is as follows:

Source	Total (US Gallons)	Total (Mega Litres)
Mission Creek	270,437,658	1,023.61
Well 4	3,772,612	14.28
Well 5	23,798,547	90.08
Well 6 (Irrigation Only)	7,063,584	26.74
Scotty Creek (Irrigation Only)	2,088	0.01
Total	305,074,489	1,154.71

2. The control gates for all of BMID's high-elevation reservoirs are closed for the season. The reservoirs will be opened after spring freshet 2024, to supplement flows in Mission Creek during the summer/fall;
3. BMID's Scotty Creek source supplying irrigation water to the north-end of the service area, was placed in stand-by mode on September 8th, 2023. The Scotty Creek source was made ready for the upcoming season on May 14th, however, the system will remain in stand-by until irrigation demands increase in the summer of 2024;
4. Well #5, used as the primary water source in the north-end of the system for both irrigation and domestic consumption, resumed operations on April 22, 2024, as system flows increased for the spring. Well #5 only operated between May 2nd and May 21st during the month, as Well #5's operation is dictated by system demand;
5. Well #4, used as a primary source for domestic water in the north-end of the distribution system during low-flow periods, resumed operation on September 27th, 2023. Well #4 was in operation between May 1st and May 6th as well as May 21st to May 31st when lower system flows matched Well #4's pumping capacities;
6. Well #6, which supplies water to the north-end irrigation distribution system, resumed operation on May 6th until May 19th when irrigation demands decreased due to the cooler and wet weather. Well# 6 will resume operations when flows increase later in the spring/summer;
7. A portion of the BMID's transmission main west of the Mission Creek Intake and east of the tunnel is located on an unstable slope. Slope movement continues to be monitored. It is currently stable and is not moving;

WATER QUALITY SUMMARY

1. No testing took place at BMID's dedicated sample station at 3976 Highway 97 due to a vehicle damaging the sample station. BMID crews will repair the sample station at a later date;
2. The WTP was in operation throughout May as Mission Creek experienced increased turbidity and colour in the raw water from spring freshet. The WTP will remain in operation until turbidity and colour levels in Mission Creek reduce in the late fall/early winter;
3. Raw water turbidity levels in Mission Creek peaked at 28.37 NTU on May 12th. Average daily raw water turbidity for May was 6.61 NTU at the Mission Creek Intake;
4. The highest turbidity level at the Distribution Intake was 1.00 NTU on May 26th, 2024. Average settled water turbidity for May was 0.54 NTU at the Distribution Intake at the lower end of Hadden Reservoir;
5. The highest turbidity level at the first customer (Booster #1) was 0.84 NTU on May 21st. Average monthly turbidity at the first customer was 0.45 NTU;
6. Average daily turbidity at the UV station peaked at 1.20 NTU on May 10th. The turbidity meter reads consistently higher at this location, however, the turbidity results upstream and downstream of the UV plant have lower turbidity results. Average monthly turbidity at the UV disinfection station was 0.83 NTU;
7. BMID's Ultraviolet Treatment Facility treated 1,023,718 m³ of water, 469 m³ of which was Off-Spec (0.046%);
8. A brief Off-Spec incident occurred on May 18, when flows at the UV treatment facility increased during the daily reactor changeover. The UV reactor responded to the change in flow appropriately, however there was a delay while the reactor increased power. Primary disinfection through chlorination was maintained throughout the incident;
9. Regarding microbiological readings, BMID ceased withdrawing water from the upper elevation reservoirs earlier in the fall of 2023. However, snowmelt in the upper watershed has led to increased, microbiological readings during the freshet period in spring 2024;
10. *E.Coli* levels at Mission Creek's Point-of-Diversion (creek intake prior to WTP) had normal counts for May. The May 13th sample had the peak monthly count of 10 coliforms. The average monthly *E.Coli* was 4.75, based on 4 samples;
11. *E.Coli* levels in the raw water at the water distribution system intake at the east end of Hadden Reservoir, immediately prior to disinfection, had zero counts on three of four samples. The fourth sample only had a single *E.Coli* count. Reduction in *E.Coli* levels is due to the effectiveness of the Water Treatment Plant as well as the settling of particles as water passes through Stevens and Hadden Reservoirs;
12. No *E.Coli* or *Total* Coliforms were found in treated water in the distribution system through third-party analysis. In addition, zero positive samples were detected by BMID's in-house presence/absence testing throughout May;

1.0 FLOWS - MAY, 2024

The Maximum Daily Flow was on May 12th, at 18,853,156 US gallons (71.36 ML)

The Minimum Daily Flow was on May 24th, at 4,485,613 US gallons (16.98 ML)

Mission Creek provided just under 89% of domestic and irrigation flow supplied in May.

Figure 1.1 - Domestic Water System Flow




Table 1.2 - May 2024 - Daily Consumption Report

Year	Mission Cr	Well #4	Well #5	Well #6	Scotty Crk	System Total	System Total
2024	Usqpd	Usqpd	Usqpd	Usqpd	Usqpd	Usqpd	ML/Day
1-May	4,670,402	228,507	0	0	0	4,898,910	18.54
2-May	5,673,781	252,018	7,133	0	0	5,932,931	22.46
3-May	6,818,649	247,527	473,921	0	0	7,540,097	28.54
4-May	5,918,694	264,170	1,120,081	0	0	7,302,945	27.64
5-May	6,686,669	301,682	1,414,366	0	0	8,402,717	31.80
6-May	7,622,789	127,066	1,267,488	472,296	0	9,489,638	35.92
7-May	7,686,692	0	1,077,285	960,432	0	9,724,409	36.81
8-May	9,029,769	0	1,199,332	128,568	0	10,357,669	39.20
9-May	11,051,768	0	1,349,645	171,072	0	12,572,484	47.59
10-May	13,661,338	0	1,689,103	546,480	0	15,896,921	60.17
11-May	15,895,520	0	1,628,344	613,536	0	18,137,400	68.65
12-May	16,244,808	0	1,684,084	924,264	0	18,853,156	71.36
13-May	15,045,996	0	1,699,141	963,864	0	17,709,001	67.03
14-May	15,414,357	0	1,670,347	885,984	2,088	17,972,776	68.03
15-May	15,757,860	0	1,634,684	823,416	0	18,215,960	68.95
16-May	15,848,075	0	1,451,614	296,472	0	17,596,161	66.60
17-May	13,338,176	0	1,364,438	162,624	0	14,865,238	56.26
18-May	9,273,917	0	1,087,060	72,336	0	10,433,312	39.49
19-May	6,525,497	0	719,335	42,240	0	7,287,072	27.58
20-May	8,232,868	0	895,008	0	0	9,127,876	34.55
21-May	8,817,559	125,745	366,140	0	0	9,309,444	35.24
22-May	5,774,192	199,448	0	0	0	5,973,641	22.61
23-May	4,270,314	222,167	0	0	0	4,492,481	17.00
24-May	4,269,257	216,355	0	0	0	4,485,613	16.98
25-May	4,709,394	214,242	0	0	0	4,923,636	18.64
26-May	4,859,391	245,414	0	0	0	5,104,805	19.32
27-May	5,450,714	204,732	0	0	0	5,655,445	21.41
28-May	5,927,095	226,130	0	0	0	6,153,225	23.29
29-May	4,552,027	192,580	0	0	0	4,744,607	17.96
30-May	5,560,134	256,245	0	0	0	5,816,379	22.01
31-May	5,849,957	248,584	0	0	0	6,098,541	23.08
Totals Usqpd	270,437,658	3,772,612	23,798,547	7,063,584	2,088	305,074,489	1154.71
Totals ML	1,023.61	14.28	90.08	26.74	0.01	1,155	
Avg's	8,723,795	33.02				9,841,113	37.25
Max	16,244,808	61.49				18,853,156	71.36
Min	4,269,257	16.16				4,485,613	16.98

2.0 RAW WATER QUALITY - BACTERIOLOGICAL MONITORING

Raw water samples were taken at three points at BMID settling ponds before chlorination.

Samples were taken at the Distribution Intake's Point of Disinfection and at the Mission Creek raw water Point of Diversion and at Stevens Pond outlet (point halfway between WTP Outlet and Distribution Intake).

Samples from the previous month are also provided to show a two-month trend

The control gates on BMID's high-elevation reservoirs were closed throughout May, resulting in a higher percentage of surface runoff and groundwater contributing to Mission Creek's flow.

Figure 2.1 - Raw Water *E.Coli* Readings (CARO Lab results) April 2024 - May 2024




Table 2.1 - *E.Coli* Readings (CARO Labs)

Date	Point of Diversion E.Coli	Stevens Outlet E.Coli	Distribution Intake E.Coli
4-Apr-24	2	1	0
8-Apr-24	2	0	0
15-Apr-24	6	0	1
22-Apr-24	2	0	0
29-Apr-24	3	0	0
6-May-24	4	0	0
13-May-24	10	0	0
21-May-24	1	1	0
27-May-24	4	0	0

Stevens or WTP Intake (Raw) - Sampling of raw water at intake from Mission Creek

Stevens Outlet (Raw) - Sampling point after exiting 142,000 m³ 1st upper balancing reservoir (Stevens Res.)

Hadden Outlet (Raw) - Sampling point after exiting 75,000 m³ 2nd lower balancing reservoir (Hadden Res.)
(Hadden Outlet = Distribution Intake - Point of Disinfection)

3.0 RAW AND TREATED WATER TURBIDITY

Through May 2024, turbidity for the Mission Creek source was measured at Booster Station No. 1 on Gallagher's Road, which is the approximate location of the first-customer. The highest turbidity level recorded at this location was 0.84 NTU on May 21st 2024. The lowest turbidity level was 0.29 NTU and the average turbidity was 0.45 NTU.

The distribution intake is where the water leaves Hadden Reservoir and enters a closed conduit. Turbidity levels are greatly reduced through the settling process as Mission Creek water makes its way through the reservoirs.

Figure 3.1 – Daily Turbidity Readings (Mission Creek Raw - Distribution Intake - Booster Station 1 and UV Plant)




Table 3.1 - Daily Monitoring Record – Turbidity at On-Line Turbidity Analysers

Turbidity Point Sampling for May 2024				
Date	Mission Creek Intake	Distribution Intake	Booster#1- First User	UV Plant
	Daily Average [NTU]	Daily Average [NTU]	Daily Average [NTU]	Daily Average [NTU]
1	2.96	0.45	0.30	0.69
2	2.46	0.47	0.32	0.72
3	2.16	0.48	0.49	0.83
4	1.99	0.49	0.33	0.77
5	2.03	0.48	0.41	0.85
6	2.64	0.48	0.40	0.82
7	2.36	0.47	0.39	0.79
8	1.96	0.52	0.57	0.92
9	2.57	0.50	0.72	1.00
10	11.05	0.49	0.80	1.20
11	25.22	0.43	0.53	0.89
12	28.37	0.40	0.44	0.87
13	23.82	0.45	0.45	0.80
14	10.84	0.50	0.50	0.86
15	10.61	0.50	0.49	0.85
16	8.82	0.50	0.52	0.88
17	8.74	0.50	0.49	0.85
18	3.97	0.49	0.41	0.86
19	2.68	0.47	0.41	0.85
20	2.26	0.47	0.42	0.84
21	2.23	0.52	0.84	1.09
22	6.77	0.34	0.69	1.10
23	8.153	0.39	0.40	0.78
24	4.93	0.50	0.39	0.77
25	3.35	0.68	0.38	0.75
26	2.46	1.00	0.37	0.73
27	2.11	0.85	0.35	0.71
28	2.27	0.54	0.33	0.67
29	8.853	0.73	0.31	0.66
30	3.98	0.83	0.32	0.67
31	2.16	0.67	0.29	0.66
AVG	6.61	0.54	0.45	0.83

4.0 CHLORINE CONTACT TIME

Temperature, pH, peak flow and chlorine residual levels are recorded to determine the CT levels that are required to provide 3 log inactivation of *Giardia*. Chlorine Contact times exceeded the CT levels required to provide 3 log (99.9%) inactivation of *Giardia Lamblia* throughout the month of May, 2024.

Figure 4.1 - CT Trending – BMID Mission Creek Source – May 2024




Table 4.2 - CT Table – Mission Creek Source

	BMID May 2024												
	Mission Creek Source												
DATE	pH	TEMP	PEAK	Free Cl2	CT	CT	CTa/CTr	Free Cl2	Cl2	VOLUME	TIME	FLOW	CL2 DOSAGE
	(Average)	(Present)	FLOW	residual	achieved	req'd		Req'd	Dosage	TOTAL		Daily Average	Average
May		[°C]	[USgpm]	[mg/L]				[mg/L]	[mg/L]	[USgal]	[mins]	[USgpm]	[PPD]
1	7.13	11.6	6422	1.28	528.1	109.8	4.81	0.27	3.5	2649600	413	3307	139.30
2	7.13	11.1	6405	1.27	525.4	113.6	4.63	0.27	3.5	2649600	414	3997	167.00
3	7.11	11.0	7076	1.36	509.3	114.7	4.44	0.31	3.4	2649600	374	4832	199.40
4	7.12	11.9	5994	1.47	649.8	109.4	5.94	0.25	3.5	2649600	442	4192	174.20
5	7.12	11.8	6422	1.38	569.3	109.1	5.22	0.26	3.4	2649600	413	4734	195.80
6	7.12	11.7	7518	1.28	451.1	108.7	4.15	0.31	3.4	2649600	352	5397	221.50
7	7.12	11.9	6976	1.36	516.6	108.1	4.78	0.28	3.4	2649600	380	5444	223.70
8	7.13	12.6	8950	1.35	399.7	103.3	3.87	0.35	3.4	2649600	296	6399	258.40
9	7.14	13.6	10924	1.38	334.7	97.1	3.45	0.40	3.3	2649600	243	7842	309.40
10	7.12	13.4	12613	1.36	285.7	97.5	2.93	0.46	3.3	2649600	210	9693	381.00
11	7.13	12.9	14516	1.18	215.4	99.1	2.17	0.54	3.3	2649600	183	11254	443.40
12	7.12	12.2	14071	1.29	242.9	105.1	2.31	0.56	3.3	2649600	188	11521	454.20
13	7.12	12.8	13097	1.25	252.9	100.3	2.52	0.50	3.3	2649600	202	10660	419.40
14	7.11	12.8	13255	1.16	231.9	98.8	2.35	0.49	3.4	2649600	200	10660	430.70
15	7.10	12.6	14228	1.17	217.9	100.0	2.18	0.54	3.3	2649600	186	10926	438.70
16	7.10	12.0	12950	1.26	257.8	105.4	2.45	0.51	3.3	2649600	205	11171	441.90
17	7.00	11.4	13700	1.45	280.4	108.0	2.60	0.56	2.8	2649600	193	11221	372.20
18	7.00	12.1	13101	1.62	327.6	104.6	3.13	0.52	2.3	2649600	202	9448	259.80
19	7.02	11.3	10049	1.23	324.3	106.9	3.03	0.41	2.4	2649600	264	6526	186.10
20	7.01	11.4	7352	1.24	446.9	105.9	4.22	0.29	4.2	2649600	360	4647	232.90
21	6.96	11.2	8385	1.32	417.1	106.3	3.92	0.34	3.6	2649600	316	5839	251.80
22	6.93	11.7	8479	1.29	403.1	101.2	3.99	0.32	2.3	2649600	312	6247	170.50
23	6.96	11.7	7820	1.33	450.6	102.8	4.38	0.30	2.6	2649600	339	4095	128.50
24	6.93	11.9	5812	1.23	560.8	99.0	5.66	0.22	3.5	2649600	456	3020	128.20
25	6.92	11.9	5324	1.23	612.2	98.7	6.20	0.20	3.9	2649600	498	3036	140.50
26	6.92	12.2	5706	1.28	594.4	97.2	6.11	0.21	3.6	2649600	464	3324	145.10
27	6.92	12.9	6054	1.18	516.4	91.5	5.65	0.21	4.0	2649600	438	3443	165.50
28	6.89	12.3	6397	1.13	468.1	93.7	5.00	0.23	3.9	2649600	414	3843	181.30
29	6.91	12.1	6134	1.22	527.0	96.8	5.44	0.22	2.8	2649600	432	4176	141.20
30	6.90	12.5	5190	1.37	699.4	95.4	7.33	0.19	4.4	2649600	511	3213	170.80
31	6.90	12.5	6046	1.34	587.3	95.1	6.17	0.22	3.8	2649600	438	3931	179.10
Average	7.04	12.10	8934	1.2987	432.38	103	4.23	0.346	3.4	2649600	333	6388	250.05

5.0 ULTRAVIOLET DISINFECTION

Total Water Treated:	1,023,718 m ³	100.00%
On-Spec Water:	1,023,249 m ³	99.954%
Off-Spec Water:	469 m ³	0.046%

Average monthly chlorine residual before UV Treatment was 1.36 mg/L
The average monthly chlorine residual after UV treatment and re-chlorination was 1.41 mg/L.

Figure 5.1 - UV Disinfection – BMID Mission Creek Source – May 2024




Table 5.2 - UV Disinfection Table – Mission Creek Source

	Inlet Cl2 Daily	Outlet Cl2 Daily	UVT	Turbidity		In Spec Water	Off Spec Water	Off Spec % of Water Volume
Date	mg/L	mg/L	% T	NTU		Cubic Meters	Cubic Meters	Percentage
1-May	1.33	1.39	88.7	0.69		17679	0	0.00%
2-May	1.38	1.42	88.4	0.72		21414	64	0.30%
3-May	1.43	1.40	88.1	0.83		25808	3	0.01%
4-May	1.37	1.40	88.1	0.77		22405	0	0.00%
5-May	1.35	1.41	87.7	0.85		25312	0	0.00%
6-May	1.38	1.41	87.7	0.82		28797	58	0.20%
7-May	1.44	1.40	87.9	0.79		29094	3	0.01%
8-May	1.44	1.42	87.8	0.92		34181	0	0.00%
9-May	1.40	1.40	87.4	1.00		41836	0	0.00%
10-May	1.44	1.45	85.9	1.20		51710	4	0.01%
11-May	1.62	1.42	86.4	0.89		60171	0	0.00%
12-May	1.56	1.42	86.8	0.87		61493	0	0.00%
13-May	1.43	1.40	86.6	0.80		56955	0	0.00%
14-May	1.51	1.44	87.6	0.86		58350	0	0.00%
15-May	1.47	1.40	87.3	0.85		59650	0	0.00%
16-May	1.39	1.40	86.7	0.88		59925	66	0.11%
17-May	1.41	1.40	86.7	0.85		50487	3	0.01%
18-May	1.51	1.41	86.9	0.86		34863	242	0.70%
19-May	1.35	1.40	85.8	0.85		24690	12	0.05%
20-May	1.38	1.41	87.6	0.84		31165	0	0.00%
21-May	1.36	1.40	88.2	1.09		33378	0	0.00%
22-May	1.23	1.39	88.9	1.10		21858	0	0.00%
23-May	1.20	1.40	89.1	0.78		16165	0	0.00%
24-May	1.20	1.40	89.0	0.77		16161	0	0.00%
25-May	1.17	1.40	89.0	0.75		17827	0	0.00%
26-May	1.22	1.40	89.1	0.73		18395	0	0.00%
27-May	1.12	1.42	88.4	0.71		20633	0	0.00%
28-May	1.33	1.48	88.8	0.67		22437	0	0.00%
29-May	1.23	1.39	88.8	0.66		17231	0	0.00%
30-May	1.25	1.42	88.7	0.67		21036	12	0.06%
31-May	1.24	1.40	88.8	0.66		22144	1	0.00%
Average	1.36	1.41	87.8	0.83	Total	1023249	469	0.046%

6.0 WATER DISTRIBUTION SAMPLING (TREATED)

Third Party Analysis (CARO Analytical Services)

- Samples taken once per week at ten locations around the BMID service area
- 24 samples were found to be absent of Coliforms.
- 24 samples were found to be absent of *E. Coli*.

Table 6.1 - CARO Independent Lab Testing – Total Coliforms – *E. Coli*

Date	2921 Beigo Rd		Booster 1		Ellison Blow-Off		Ellison School		3976 Highway 97		Prospect Reservoir		Tower Reservoir		Well #4		Kirschner Res		Pearson School	
	Coliforms	E.coli	Coliforms	E.coli	Coliforms	E.coli	Coliforms	E.coli	Coliforms	E.coli	Coliforms	E.coli	Coliforms	E.coli	Coliforms	E.coli	Coliforms	E.coli	Coliforms	E.coli
4-Apr-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
8-Apr-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
15-Apr-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
22-Apr-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
29-Apr-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
6-May-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
13-May-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
21-May-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
27-May-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

In-House Analysis (BMID Staff)

- Presence/Absence samples taken on a three-week cycle at seven sites around the BMID service area.
- All 10 samples were found to be absent of both *Total Coliforms* and *E. Coli*.

Table 6.2 - BMID In-house Testing – Presence Absence

Location	5/6/2024				5/13/2024				5/20/2024				5/27/2024			
	CI2	Temp.	Pres.	Abs.	CI2	Temp.	Pres.	Abs.	CI2	Temp.	Pres.	Abs.	CI2	Temp.	Pres.	Abs.
Sylvania Cres	0.75	16.4	-	X									0.86	17.2	-	X
170 Kneller Rd	0.74	16.8	-	X									0.82	17.2	-	X
2105 Morrison					1.04	17.2	-	X								
Staymen Rd					0.69	17.4	-	X								
260 Campion Rd									0.10	16.2	-	X				
Fenwick Rd									0.44	14.4	-	X				
Solly Ct	0.83	14.4	-	X									0.09	16.6	-	X

- BMID Population = 28,000

RECOMMENDED TESTS

- Recommended number of samples per month = 28
(as per Guide for Canadian Drinking Water Quality)

ACTUAL TESTS

- Total tests by BMID staff (presence/absence) = 10
- Total tests sampled by BMID and tested by Caro Labs 24
- Total tests sampled in BMID treated distribution system = 34
- 0 Positive *E. Coli* and Total Coliform Samples